

ZERTIFIKAT ◆ CERTIFICATE ◆ CERTIFICADO ◆ CERTIFIKAT ◆ 認 証 証 書

# EC Attestation of Conformity



No.: N8 03 05 49965 001

O-Sung Electric Machinery Co., Ltd.

#111-3, Youngtae-Ri, Woollong-Myun,  
Paju-City, Kyungki-Do,  
Korea

**Product:** Electrical equipment acc. to the Low Voltage Directive  
(ATSE(Automatic Transfer Switching Equipment))

**Model:** SS-62-TN

**Parameters:**

Rated operational voltage (Ue):	230 Va.c.
Rated frequency:	50/60 Hz
Utilization category:	AC-33B
Rated operational current (Ie):	200A
Rated short-time making capacity (Icm):	10kA
Rated short-time withstand current (Icw):	10kA / 0.03s

The equipment complies with the principal protection requirements of the Low Voltage Directive (Directive 73/23/EEC relating to electrical equipment designed for use within certain voltage limits) based on a voluntary test.

This attestation applies only to the particular sample of the product provided for testing and certification. The detailed test results and all standards used as well as the operation mode are listed in

Test report no. CPSA0112613

Test standards: EN 60947-6-1/A2:1997

This attestation is released with the above mentioned attestation number by the Certification Body of TÜV PRODUCT SERVICE. It does not permit the use of a TÜV PRODUCT SERVICE certification mark.

After preparation of the necessary technical documentation as well as the conformity declaration the CE marking as shown below can be affixed on the equipment. Other relevant Directives have to be observed.



Department:  
Date:

ELSKR / jwy  
May-12-2003